

Reference: RFI 1711118

**Request:**

**Follow on request following response to RFI 1710034**

Under the Freedom of Information Act 2000, please could you also confirm for us the capacity of the road drains and gullies servicing 66 Briar Vale, Whitley Bay, NE25 9AZ and the surrounding properties as of 28th June 2012 and 21st November 2016 (if they are different)?

**Response:**

The design of the surface water network is undertaken by the developer's consultant and eventually accepted by Northumbrian Water (NWL) as part of the adoption of sewer process.

As per Sewers for Adoption, the surface water network should have been designed for 1 in 30 year return period rainfall event with no flooding.

North Tyneside Council do not possess the data on surface water modelling, as this was carried out by NWL / Developers Consultants.